Danfoss AVTA Thermostatic Valves — Self-Acting Cooling Control Without Electricity

cBallast Technical Sourcing · Self-acting temperature control · issued 2026-10-18 · cballast.com/documents/danfoss-avta-thermostatic-water-valves

How the AVTA opens cooling water in exact proportion to temperature with no power, controller or actuator — charge types (adsorption vs vapour) and when each wins, valve sizing by the cooling duty rather than the pipe, and the element and diaphragm spares that keep thirty-year-old valves regulating.

A controller, sensor and actuator in one casting

The AVTA is the industrial classic of self-acting control: a sensor bulb charged with a temperature-responsive medium drives a bellows through a capillary, which strokes the valve directly. Sensed temperature rises !’ valve opens !’ more cooling water !’ temperature falls. No power, no panel, no tuning beyond the setpoint knob — which is why oil coolers, compressor jackets, hydraulic systems, welding gear and sample coolers run it for decades. The stocked range shows the connection spread: AVTA 15 with NPT 1/2 3 and the R1/2 3 version, 25–65 °C range, 2 m capillary — the range in the reference is the adjustable setpoint span.

Charge type: the one spec people miss

Charge | Behaviour | Choose when |

Adsorption | Sensor must be the system's coldest point is not required — the charge sits in the bulb regardless of capillary/valve temperature | Valve or capillary may run warmer or colder than the bulb — the robust industrial default; the stocked adsorption-charge element serves it |

Vapour | Charge condenses at the coldest point, so the bulb must stay warmest; crisper action near setpoint | Controlled placement guarantees bulb-warmest — common in tight spans |

Replacement elements (universal AVTA/AVTB element) and NBR diaphragm sets are stocked line items — a weeping or sluggish AVTA is almost always an element or diaphragm renewal, not a new valve, and both fit in-line in minutes.

Sizing and installing

Size by kv and the cooling duty — required water flow at the available differential — not by matching the pipe. Over-sized valves hunt; the correct AVTA is often one size under the line.

Setpoint span must bracket the target: the 25–65 °C row suits machine cooling; other spans exist per reference.

Bulb placement is the control loop: in the hottest representative flow, fully immersed, with the capillary unkinked and away from heat tracing. Pockets (thermowells) trade a little speed for serviceability.

Water-side strainer upstream (strainer guide) — seat erosion from grit is the one failure spares do not fix cheaply.

Electric-actuation alternatives and cross-brands (Penn V46 family) are compared in the water-regulating valve guide; sensor-side theory in the temperature-sensor finder.

Around 55 AVTA-line items — valves, elements, diaphragms — are stocked under Danfoss; the valve's stamped reference plus setpoint range quotes one-for-one within 24 hours.

Frequently asked questions
How does an AVTA valve work without electricity?A charged sensor bulb expands against a bellows through a capillary tube, stroking the valve plug directly — sensed heat literally pushes the valve open. The whole control loop is thermomechanical, which is why it runs for decades unattended.Which way does an AVTA respond — open or close on rising temperature?The standard cooling-duty build opens on rising bulb temperature (more cooling water as things get hot) and closes as it cools, throttling proportionally around the setpoint rather than snapping.What is the difference between adsorption and vapour charge?Where the charge lives: adsorption binds it in the bulb so placement is forgiving; vapour charge migrates to the coldest point, demanding the bulb stay warmest, in exchange for crisp response. Replacement elements state their charge — match it.Why does my AVTA no longer reach setpoint?In order of likelihood: lost charge in the element (fit the stocked replacement), perished diaphragm, scaled/eroded seat from unstrained water, or a bulb no longer immersed in representative flow. Elements and diaphragm sets renew in place.Can the AVTA control heating instead of cooling?Reverse-acting variants and the AVTB sibling cover heating duty — the reference, not an adjustment, determines action. Specify duty (open/close on rise) when quoting anything beyond standard cooling service.

Part numbers and designations are those of the original manufacturers and are given for identification. cBallast is an independent supplier. © cBallast 2026 · cballast.com