



DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6509CL0521

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Grohe AG Industriepark Edelburg, D-58675 Hemer
Distributor <i>Vertreiber</i>	Grohe AG Industriepark Edelburg, D-58675 Hemer
Product Category <i>Produktart</i>	Sanitary tapware: Thermostatic mixing valves (6509)
Product description <i>Produktbezeichnung</i>	Thermostatic mixer as scalding protection without actuating member to adjust the flow rate
Model <i>Modell</i>	Grohtherm Micro
Test reports <i>Prüfberichte</i>	Laboratory control test: DE25CJ8M 001 from 10.12.2025 (LGW) Type testing: 170801529/001e from 16.07.2018 (KIW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 574 (01.04.2007) DIN EN 1111 (01.10.2017)

Date of Expiry / File No. 10.12.2030 / 25-1044-WNV
Ablaufdatum / Aktenzeichen

70025-04-A-DE

06.01.2026 Swd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dv-gw-cert.com
www.dv-gw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Grohtherm Micro	Noise emission class: I Pressure rating: PN 10 Nominal diameter: 3/8"	AbP: P-IX 28356/IA

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. Registr.-Nr.	Component Bauteil (Produktart)	Model/Type Modell/Typ	Manufacturer Hersteller
NW-6312AS2272	plug-in non-return valve	DW.../DW14, DW14-pr, DW14-AF-pr, DW15	NEOPERL GmbH
DW-0304BO7088	Flexible pressure hose, class I	SOFTPEX® (SST) DN 6 / DN 8/SP® DN 10	NEOPERL GmbH

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

The hygienic safety of all materials that come into contact with drinking water has been proven.

undersink thermostatic mixer: article number: 34487000

connection set: article number: 47533000

