

Ahlsell a-collection safety valve AVI1890-S and safety valve group AVI1898-S

Holder/Issued to

Ahlsell AB

Årstaängsvägen 11, 117 43 Stockholm, Sverige.

Product description

Safety valve and safety valve group in lead-free brass with EPDM seal.

Intended use

Safety valve for cold and hot tap water.

Trade name

Ahlsell a-collection safety valve AVI 1890-S G1/2" male thread
RSK 5075108 (6 bar), RSK 5075109 (9 bar), and RSK 5075110 (10 bar)

Ahlsell a-collection safety valve AVI 1890-S G3/4" x G3/4" female thread
RSK 5075127 (6 bar), RSK 5075128 (8 bar), and RSK 5075129 (10 bar)

Ahlsell a-collection safety valve group AVI 1898-S G3/4" 6, 8, 10 bar
RSK 5029013 (6 bar), RSK 5029014 (8 bar), and RSK 5029015 (10 bar)

Approval

The products comply with the requirements of Chapter 8, Section 4, item 3 of the Planning and Building Act (2010:900), in the respects and under the conditions specified in this type approval.

The products meet the requirements of Chapter 4, Sections 12 of the Planning and Building Ordinance (2024:134) and has been assessed to not release harmful concentrations of hazardous substances into drinking water, not promote microbial growth, and not negatively affect the color, odor, or taste of the water.

The approval covers the parts of the Swedish National Board of Housing, Building and Planning's (Boverket's) regulations and general recommendations specified below:

Boverket's regulations with regard to hygiene, health and the environment, water management and waste management (BFS 2024:8):

Water- and sewage installations

BFS 2024:8, Ch. 8, Sec. 3, 4 and 6

Boverket's Building Regulations (BBR) (BFS 2011:6 as amended up to and including BFS 2024:5)¹:

Installation of Tapwater

BBR 6:62

¹ May be applied to the extent stated in the transitional provisions of Boverket's regulations BFS 2024:14.

Associated documents

n/a

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. CR074 dated 2018-10-10 Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing places

Production control includes the following places:

Ahlsell AB, Terminalgatan 3, 694 81, Hallsberg, Sweden and manufacturing unit 954169

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Holder	Ahlsell AB
Product type designation	Trade name
Consecutive date of production	YY/WW
Type approval number	C901313
Boverket's registered trade mark	
RISE Accreditation number	1002
Inspection body	RISE

Basis for approval

Report O100115-1259945-C from RISE

Certificate HW-0804DO0113 from DVGW

Comments

documents shall accompany the product or by other means be available to users of the product.

This type approval supersedes the previous type approval with the same number dated 2025-03-25.

Validity

Valid up to and including 2030-03-24

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved products with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011 or 2024/3110.

A handwritten signature in blue ink, appearing to read "Stefan Coric".

Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.