

Ahlsell a-collection butterfly valve AVI 1483

Holder/Issued to**Ahlsell AB**

Årstaängsvägen 11, 117 43 Stockholm, Sverige.

Product description

Soft-sealing butterfly valve AVI 1483 with EPDM lining. Wafer model for clamping between flanges and LUG model with threaded connection.

Intended use

Butterfly valve is intended for use in applications where it comes into contact with drinking water.

Trade name

Ahlsell a-collection butterfly valve AVI 1483

Approval

The product satisfy the requirements set forth in chapter 8, 4 § 3 PBL (2010:900), in respect to and under conditions stated in this type approval.

The product meets the requirements of Chapter 4, Sections 12 and 13 of the Planning and Building Ordinance (2024:134) and has been assessed not to release unhealthy concentrations of harmful substances into drinking water and not to promote microbial growth or negatively affect the water's color, odor, or taste at temperatures up to 85°C.

The type approval covers the parts of the Swedish Building Regulations (BBR) specified below:

Tap water installations

6:62, 1st sentence and 2nd paragraph and general recommendation

Associated documents

-

Control

The factory production control (FPC) is monitored by an independent inspection body.

Control plan: Ref no. CR074 dated 2018-10-10, Inspection body: RISE

When the building proprietor performs inspection at the building site, markings shall be checked to ensure that the correct products have been supplied and that they are used in accordance with the conditions in this type approval. Further the product shall be accompanied by a manufacturer's assurance, certifying that the product has been manufactured in accordance with the documents on which this type approval is based.

Manufacturing place

Production control includes the following place:
Manufacturing place 971000

Marking

The products are to be marked at the factory. The marking consists of a text on every product and packing supplied and includes:

Holder	Ahlsell AB
Product type designation	Trade name
Consecutive date of production	YY/WW
Type approval number	C901279
Boverket's registered trade mark	
RISE Accreditation number	1002
Inspection body	RISE

Basis for approval

Report DL-82277 from D-LAB
Report 23-00483-AB01 from DVGW
Certificate HW-0804DO0240 from DVGW

Comments

-

Validity

Valid through 2030-05-12.

The validity of this type approval can be verified at RISE homepage.

The validity of this type approval expires when the type approved product with the intended use according to this type approval shall be CE-marked according to the Construction Products Regulation (EU) 305/2011.



Stefan Coric

This is a translation from the Swedish original document. In the event of any dispute as to its content, the Swedish original shall take precedence.