

Specifications

Eaton 106833

Eaton Moeller® series LS Actuator, flat



General specifications

PRODUCT NAME	Eaton Moeller® series LS Actuator
CATALOG NUMBER	106833
MODEL CODE	LS-XG-ZBZ
EAN	4015081065936
PRODUCT LENGTH/DEPTH	44 mm
PRODUCT HEIGHT	2 mm
PRODUCT WIDTH	35 mm
PRODUCT WEIGHT	0.011 kg
CERTIFICATIONS	CSA Class No.: 3211-03 CSA File No.: 012528 UL 508 IEC/EN 60947-5 UL Category Control No.: NKCR CSA CSA-C22.2 No. 14 UL CE UL File No.: E29184 IEC/EN 60947



Powering Business Worldwide

Actuator

MECHANICAL HOLDING FORCE

1600 N (according to GS-ET-19 (04/2004), XWA, XFG, XF)
1700 N (according to GS-ET-19 (04/2004), XG, XW, XNG)
1200 N (according to GS-ET-19 (04/2004), XNW)

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MAX

40 °C

AMBIENT OPERATING TEMPERATURE - MIN

-25 °C

CLIMATIC PROOFING

Damp heat, cyclic, to IEC 60068-2-30
Damp heat, constant, to IEC 60068-2-78

Ambient conditions, mechanical

MOUNTING POSITION

As required

SHOCK RESISTANCE

10 g, Standard-action contact, Mechanical, Half-Sinusoidal shock 20 ms

Design verification

10.10 TEMPERATURE RISE

Not applicable.

10.11 SHORT-CIRCUIT RATING

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 ELECTROMAGNETIC COMPATIBILITY

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 MECHANICAL FUNCTION

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

10.2.2 CORROSION RESISTANCE

Meets the product standard's requirements.

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES

Meets the product standard's requirements.

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT

Meets the product standard's requirements.

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS

Meets the product standard's requirements.

10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION

Please enquire

10.2.5 LIFTING

Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 MECHANICAL IMPACT

Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 INSCRIPTIONS

Meets the product standard's requirements.

10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W

Features & functions

FUNCTIONS	For combination with LS-...ZBZ/X basic devices
MATERIAL	Stainless steel

General information

DUTY FACTOR	100 %
MODEL	Standard actuator
OPERATING FREQUENCY	800 Operations/h
TYPE	• Actuator • Flat actuator

Resources

CATALOGUES	eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf eaton-product-overview-for-machinery-catalogue-ca08103003zen-en-us.pdf
DRAWINGS	eaton-position-switches-straight-actuator-ls-actuator-dimensions.eps eaton-position-switches-ls-actuator-3d-drawing.eps
INSTALLATION INSTRUCTIONS	eaton-ls-s-zbz-safety-position-switch-instruction-leaflet-il05208005z.pdf
MCAD MODEL	eaton-accessories-mcad-drawings-ls-betaetiger-zbz3.dwg ls_betaetiger_zbz3.stp
SALES NOTES	eaton-safety-switches-rs-titan-flyer-fl053001en-en-us.pdf

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2026 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

