

# Specifications



## Eaton 183911

Eaton Moeller series IZMX/INX - ACB. Circuit-breaker, 4p, 1000A, 105 kA, Selective operation, IEC, Fixed

### General specifications

|                             |                                               |
|-----------------------------|-----------------------------------------------|
| <b>PRODUCT NAME</b>         | Eaton Moeller series IZMX/INX circuit-breaker |
| <b>CATALOG NUMBER</b>       | 183911                                        |
| <b>MODEL CODE</b>           | IZMX40H4-V10F-1                               |
| <b>EAN</b>                  | 4015081790555                                 |
| <b>PRODUCT LENGTH/DEPTH</b> | 584 mm                                        |
| <b>PRODUCT HEIGHT</b>       | 597 mm                                        |
| <b>PRODUCT WIDTH</b>        | 521 mm                                        |
| <b>PRODUCT WEIGHT</b>       | 56 kg                                         |
| <b>COMPLIANCES</b>          | IEC<br>IEC/EN 60947<br>RoHS conform           |

## Delivery programme

|                        |                                                              |
|------------------------|--------------------------------------------------------------|
| <b>AMPERAGE RATING</b> | 1000 A                                                       |
| <b>FEATURES</b>        | Motor drive optional<br>Complete device with protection unit |
| <b>FITTED WITH:</b>    | Switched-off indicator                                       |
| <b>FRAME</b>           | IZMX40                                                       |
| <b>NUMBER OF POLES</b> | Four-pole                                                    |
| <b>RELEASE SYSTEM</b>  | Electronic release                                           |

### SPECIAL FEATURES

- Main terminals must be separately ordered.
- suitable for zone selectivity
- optionally fittable by user with comprehensive accessories
- Terminal capacity hint: These are values used in separate switchgear. The actual values will depend on the temperature around the circuit breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.

### TYPE

- Air circuit breakers/switch-

## Design verification to IEC/EN 61439

|                                                                                         |                                                                                                                                  |
|-----------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------|
| <b>10.10 TEMPERATURE RISE</b>                                                           | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| <b>10.11 SHORT-CIRCUIT RATING</b>                                                       | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.12 ELECTROMAGNETIC COMPATIBILITY</b>                                              | Is the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| <b>10.13 MECHANICAL FUNCTION</b>                                                        | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |
| <b>10.2.2 CORROSION RESISTANCE</b>                                                      | Meets the product standard's requirements.                                                                                       |
| <b>10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES</b>                         | Meets the product standard's requirements.                                                                                       |
| <b>10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT</b>       | Meets the product standard's requirements.                                                                                       |
| <b>10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS</b> | Meets the product standard's requirements.                                                                                       |
| <b>10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION</b>                                 | Meets the product standard's requirements.                                                                                       |
| <b>10.2.5 LIFTING</b>                                                                   | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| <b>10.2.6 MECHANICAL IMPACT</b>                                                         | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| <b>10.2.7 INSCRIPTIONS</b>                                                              | Meets the product standard's requirements.                                                                                       |
| <b>10.3 DEGREE OF PROTECTION OF ASSEMBLIES</b>                                          | Does not apply, since the entire switchgear needs to be evaluated.                                                               |
| <b>10.4 CLEARANCES AND CREEPAGE DISTANCES</b>                                           | Meets the product standard's requirements.                                                                                       |

|                  |                                                                  |
|------------------|------------------------------------------------------------------|
|                  | disconnectors<br>• Open circuit breaker                          |
| <b>USED WITH</b> | Open circuit breaker<br>Air circuit breakers/switch-disconnector |

|                                                                 |                                                                    |
|-----------------------------------------------------------------|--------------------------------------------------------------------|
| <b>10.5 PROTECTION AGAINST ELECTRIC SHOCK</b>                   | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS</b>   | Does not apply, since the entire switchgear needs to be evaluated. |
| <b>10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS</b>        | Is the panel builder's responsibility.                             |
| <b>10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS</b>                 | Is the panel builder's responsibility.                             |
| <b>10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH</b>                 | Is the panel builder's responsibility.                             |
| <b>10.9.3 IMPULSE WITHSTAND VOLTAGE</b>                         | Is the panel builder's responsibility.                             |
| <b>10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL</b> | Is the panel builder's responsibility.                             |

## Design verification to IEC/EN 61439 - technical data

|                                                                      |                |
|----------------------------------------------------------------------|----------------|
| <b>AMBIENT OPERATING TEMPERATURE - MAX</b>                           | 70 °C          |
| <b>AMBIENT STORAGE TEMPERATURE - MAX</b>                             | 70 °C          |
| <b>AMBIENT OPERATING TEMPERATURE - MIN</b>                           | -20 °C         |
| <b>AMBIENT OPERATING TEMPERATURE DETAILS</b>                         | -20 °C - 70 °C |
| <b>AMBIENT STORAGE TEMPERATURE - MIN</b>                             | -20 °C         |
| <b>EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT</b>                 | 40 W           |
| <b>HEAT DISSIPATION AT RATED CURRENT WITH FIXED MOUNTING</b>         | 40 W           |
| <b>RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)</b> | 1000 A         |

## Technical data - electrical

|                                                                        |                                                                                                       |
|------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------|
| <b>ACTUATOR TYPE</b>                                                   | Push button                                                                                           |
| <b>ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MAX</b> | 10000 A                                                                                               |
| <b>ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MIN</b> | 600 A                                                                                                 |
| <b>ADJUSTMENT RANGE UNDELAYED SHORT-CIRCUIT RELEASE - MAX</b>          | 15000 A                                                                                               |
| <b>ADJUSTMENT RANGE UNDELAYED SHORT-CIRCUIT RELEASE - MIN</b>          | 2000 A                                                                                                |
| <b>CLOSING DELAY VIA SPRING RELEASE</b>                                | 35 ms                                                                                                 |
| <b>DIRECTION OF INCOMING SUPPLY</b>                                    | As required                                                                                           |
| <b>ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT</b>                      | Rail connection                                                                                       |
| <b>LIFESPAN, ELECTRICAL</b>                                            | 20000 operations (switching cycles ON/OFF, with maintenance)<br>10000 operations (switching capacity) |
| <b>NUMBER OF STANDARD MECHANICAL OPERATIONS PER HOUR -</b>             | 60                                                                                                    |

|                                                                          |               |
|--------------------------------------------------------------------------|---------------|
| <b>MAX</b>                                                               |               |
| <b>OPERATING SEQUENCE<br/>UP TO 690 V, 50/60 HZ<br/>(IEC/EN 60947)</b>   | 85 kA         |
| <b>OVERLOAD RELEASE<br/>CURRENT SETTING - MAX</b>                        | 1000 A        |
| <b>OVERLOAD RELEASE<br/>CURRENT SETTING - MIN</b>                        | 400 A         |
| <b>OVERVOLTAGE<br/>CATEGORY</b>                                          | III           |
| <b>POLLUTION DEGREE</b>                                                  | 3             |
| <b>RATED IMPULSE<br/>WITHSTAND VOLTAGE<br/>(UIMP)</b>                    | 12 kV AC      |
| <b>RATED INSULATION<br/>VOLTAGE (UI)</b>                                 | 1000 V        |
| <b>RATED OPERATING<br/>VOLTAGE (UE) - MAX</b>                            | 690 V         |
| <b>RATED OPERATING<br/>VOLTAGE (UE) - MIN</b>                            | 240 V         |
| <b>RATED SHORT-CIRCUIT<br/>BREAKING CAPACITY AT<br/>400 V, 50 HZ</b>     | 105 kA        |
| <b>RATED SHORT-CIRCUIT<br/>MAKING CAPACITY UP TO<br/>440 V, 50/60 HZ</b> | 231 kA        |
| <b>RATED SHORT-CIRCUIT<br/>MAKING CAPACITY UP TO<br/>690 V, 50/60 HZ</b> | 166 kA        |
| <b>RATED SHORT-TIME<br/>WITHSTAND CURRENT (T<br/>= 1 S)</b>              | 85 kA         |
| <b>RATED SHORT-TIME<br/>WITHSTAND CURRENT AT<br/>50/60 HZ (T = 3 S)</b>  | 66 kA         |
| <b>RATED UNINTERRUPTED<br/>CURRENT (IU)</b>                              | 1000 A        |
| <b>RATED UNINTERRUPTED<br/>CURRENT (IU) AT 50°C</b>                      | 1000 A        |
| <b>RATED UNINTERRUPTED<br/>CURRENT (IU) AT 60°C</b>                      | 1000 A        |
| <b>RATED UNINTERRUPTED<br/>CURRENT (IU) AT 70°C</b>                      | 1000 A        |
| <b>SHORT-CIRCUIT RELEASE<br/>DELAYED SETTING - MAX</b>                   | 10000 A       |
| <b>SHORT-CIRCUIT RELEASE<br/>DELAYED SETTING - MIN</b>                   | 750 A         |
| <b>SHORT-CIRCUIT RELEASE<br/>NON-DELAYED SETTING</b>                     | 1.5 - 10 x Ir |
| <b>SHORT-CIRCUIT RELEASE<br/>NON-DELAYED SETTING -</b>                   | 15000 A       |

## Technical data - mechanical

|                             |                                                            |
|-----------------------------|------------------------------------------------------------|
| <b>DEGREE OF PROTECTION</b> | IP55 with protective cover<br>IP31<br>IP31 with door seals |
|-----------------------------|------------------------------------------------------------|

|                            |                                          |
|----------------------------|------------------------------------------|
| <b>DEVICE CONSTRUCTION</b> | Built-in device fixed built-in technique |
|----------------------------|------------------------------------------|

|                             |                                                                                            |
|-----------------------------|--------------------------------------------------------------------------------------------|
| <b>LIFESPAN, MECHANICAL</b> | 12500 switching cycles (ON/OFF)<br>25000 operations (switching capacity, with maintenance) |
|-----------------------------|--------------------------------------------------------------------------------------------|

|                        |       |
|------------------------|-------|
| <b>MOUNTING METHOD</b> | Fixed |
|------------------------|-------|

|                                                            |   |
|------------------------------------------------------------|---|
| <b>NUMBER OF AUXILIARY CONTACTS (CHANGE-OVER CONTACTS)</b> | 2 |
|------------------------------------------------------------|---|

|                                                                |   |
|----------------------------------------------------------------|---|
| <b>NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)</b> | 0 |
|----------------------------------------------------------------|---|

|                                                              |   |
|--------------------------------------------------------------|---|
| <b>NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)</b> | 0 |
|--------------------------------------------------------------|---|

|                                                        |           |
|--------------------------------------------------------|-----------|
| <b>POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT</b> | Back side |
|--------------------------------------------------------|-----------|

|                   |                     |
|-------------------|---------------------|
| <b>PROTECTION</b> | Selective operation |
|-------------------|---------------------|

|                                                  |       |
|--------------------------------------------------|-------|
| <b>WEIGHT OF FIXED MOUNTING VERSION (4-POLE)</b> | 56 kg |
|--------------------------------------------------|-------|

## MAX

|                                                        |     |
|--------------------------------------------------------|-----|
| <b>SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN</b> | 0 A |
|--------------------------------------------------------|-----|

|                             |   |
|-----------------------------|---|
| <b>UTILIZATION CATEGORY</b> | B |
|-----------------------------|---|

|                             |          |
|-----------------------------|----------|
| <b>VOLTAGE RATING AT AC</b> | 690 V AC |
|-----------------------------|----------|

## Technical data - mechanical - terminals

|                                       |                                               |
|---------------------------------------|-----------------------------------------------|
| <b>TERMINAL CAPACITY (COPPER BAR)</b> | 60 mm x 10 mm (1x) for fixed mounting (black) |
|---------------------------------------|-----------------------------------------------|

## Resources

|                            |                                                                                 |
|----------------------------|---------------------------------------------------------------------------------|
| CATALOGUES                 | <a href="#">eaton-acb-izmx-catalog-ca01305001z-en-us.pdf</a>                    |
| DECLARATIONS OF CONFORMITY | <a href="#">eaton-circuit-breaker-declaration-of-conformity-eu250301en.pdf</a>  |
| DRAWINGS                   | <a href="#">eaton-circuit-breaker-mounting-izmx-inx-mccb-dimensions-002.eps</a> |
|                            | <a href="#">eaton-circuit-breaker-izmx-inx-mccb-dimensions-013.eps</a>          |
|                            | <a href="#">eaton-circuit-breaker-mounting-izmx-inx-mccb-dimensions.eps</a>     |
| ECAD MODEL                 | <a href="#">DA-CE-ETN.IZMX40H4-V10F-1</a>                                       |
| INSTALLATION VIDEOS        | <a href="#">Air Circuit Breakers Series IZMX</a>                                |
| MANUALS AND USER GUIDES    | <a href="#">MN013002_EN</a>                                                     |
| MCAD MODEL                 | <a href="#">DA-CS-izmx40_4pol_f</a>                                             |
|                            | <a href="#">eaton-air-circuit-breakers-mcad-drawings-izmx40-4pol-f.dwg</a>      |

---

**PROJECT NAME:**

**PROJECT NUMBER:**

**PREPARED BY:**

**DATE:**

---



**Eaton Corporation plc** Eaton House  
30 Pembroke Road  
Dublin 4, Ireland  
Eaton.com

© 2026 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

