

Specifications



Eaton 187098

Eaton Moeller® series M30 Key-operated actuator, Flat Front, maintained, 3 positions, Ronis 455, Key withdrawable: I, 0, II, Metal bezel

General specifications

PRODUCT NAME	Eaton Moeller® series M30 key-operated actuator
---------------------	---

CATALOG NUMBER	187098
-----------------------	--------

MODEL CODE	M30C-FWRS3-RS
-------------------	---------------

EAN	4015081821525
------------	---------------

PRODUCT LENGTH/DEPTH	36 mm
-----------------------------	-------

PRODUCT HEIGHT	67 mm
-----------------------	-------

PRODUCT WIDTH	46 mm
----------------------	-------

PRODUCT WEIGHT	0.06 kg
-----------------------	---------

CERTIFICATIONS	VDE 0660 IEC/EN 60947 CSA file No. 012528 CSA Class No.: 3211-03 DNV UL File No.: E29184 GL IEC/EN 60947-5 UL 508 CSA-C22.2 No. 14-05 CSA-C22.2 No. 94-91 CE marking UL Category Control No.: NKCR UL Listed CSA certified
-----------------------	--

Actuator

ACTUATOR COLOR	Black
ACTUATOR FUNCTION	Maintained Switching function latching Key withdrawable in position 2 Key withdrawable in position 0 Key withdrawable in position 1
ACTUATOR TYPE	Key
BEZEL COLOR	Titanium
BEZEL MATERIAL	Metal
DESIGN	Key operation lock mechanism Flat front
FITTED WITH:	Plunger bridge for the middle contact Front ring
FUNCTIONS	Stay-put/spring-return function, can be changed with coding parts M22-XC-Y
INDICATOR COLOR	Other
KEY CODE	Ronis 455
LENS TYPE	Round
NUMBER OF SWITCH POSITIONS	3

Communication

CONNECTION TO SMARTWIRE-DT	With SWD-RMQ connections Yes
-----------------------------------	---------------------------------

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30

Design verification

10.10 TEMPERATURE RISE	Not applicable.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF	Meets the product

THERMAL STABILITY OF ENCLOSURES	standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Please enquire
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER	0 W

POLE, CURRENT-DEPENDENT PVID**RATED OPERATIONAL
CURRENT FOR SPECIFIED
HEAT DISSIPATION (IN)** 0 A**STATIC HEAT
DISSIPATION, NON-
CURRENT-DEPENDENT
PVS** 0 W**General information****ACCESSORIES** 2 keys included with supplied equipment.**DEGREE OF PROTECTION** NEMA 4X, 13**DEGREE OF PROTECTION
(FRONT SIDE)** IP64**LIFESPAN, MECHANICAL** 100,000 Operations**MOUNTING POSITION** As required**OPENING DIAMETER** 30 mm**OPERATING FREQUENCY** 100 Operations/h**OPERATING TORQUE** 0.5 Nm**OVERVOLTAGE
CATEGORY** III**POLLUTION DEGREE** 3**PRODUCT CATEGORY** RMQ-Titan**SIZE** Front dimensions: Ø 36 mm**SWITCHING ANGLE** 60 °**TYPE** Key-operated button**Resources**CATALOGUES [eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)DECLARATIONS OF CONFORMITY [eaton-illuminated-pushbutton-declaration-of-conformity-eu251546en.pdf](#)DRAWINGS [eaton-operating-m30-dimensions-004.eps](#)
[eaton-operating-m30-key-operated-actuator-dimensions-003.eps](#)
[eaton-operating-m30-dimensions-005.eps](#)
[eaton-operating-m30-dimensions-006.eps](#)
[eaton-operating-m30-key-operated-actuator-3d-drawing-003.eps](#)
[eaton-general-approval-m22-symbol.eps](#)
[eaton-general-m22-symbol.eps](#)ECAD MODEL [ETN.187098.edz](#)INSTALLATION INSTRUCTIONS [eaton-operating-devices-m30-rmq-titan-flat-front-instruction-leaflet-il047019zu.pdf](#)MCAD MODEL [DA-CS-schluesseltaste_rs_flatfront](#)
[eaton-switches-mcad-drawings-schluesseltaste-rs.dwg](#)

PROJECT NAME:
PROJECT NUMBER:
PREPARED BY:
DATE:



Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2026 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

