

Specifications



Photo is representative

Eaton 192385

Eaton Moeller® series EMS2 DOL starter, 24 V DC, 0,18 - 3 A, Push in terminals, SmartWire-DT slave, Controlled stop, PTB 19 ATEX 3000

General specifications

PRODUCT NAME	Eaton Moeller® series EMS2 DOL starter
CATALOG NUMBER	192385
MODEL CODE	EMS2-DOS-T-3-SWD
EAN	4015081930821
PRODUCT LENGTH/DEPTH	114.5 mm
PRODUCT HEIGHT	99 mm
PRODUCT WIDTH	22.5 mm
PRODUCT WEIGHT	0.297 kg
CERTIFICATIONS	EN ISO 13849 IEC 61508 IEC/EN 60947-4-2 UL508 UL File No.: E338590 UL Category Control No.: NLDX, NLDX7 PTB 19 ATEX 3000 UL 60947-4-1 CSA-C22.2 No. 60947-4-1-14 CE marking UL listed Certified by UL for use in Canada UL report applies to both US and Canada

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MAX	55 °C
--	-------

AMBIENT STORAGE TEMPERATURE - MAX	80 °C
--	-------

AMBIENT OPERATING TEMPERATURE - MIN	-5 °C
--	-------

AMBIENT STORAGE TEMPERATURE - MIN	40 °C
--	-------

Contacts

NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
--	---

NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
--	---

Design verification

10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION	Does not apply, since the

Electrical rating

INRUSH CURRENT	120 mA (draw)
RATED ACTUATING CURRENT (IC)	5 mA
RATED CONTROL SUPPLY CURRENT IS	60 mA
RATED CONTROL SUPPLY VOLTAGE	19.2 - 30 V DC
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	24 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	24 V
RATED CONTROL VOLTAGE (UC)	24 V (Actuating circuit ON, L, R)
RATED OPERATIONAL CURRENT (IE)	3 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	3 A
RATED OPERATIONAL CURRENT (IE) AT AC-51	3 A
RATED OPERATIONAL CURRENT (IE) AT AC-53A - MAX	3 A
RATED OPERATIONAL POWER AT AC-3, 220/230 V, 50 HZ	0.55 kW
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	1.1 kW
RATED OPERATIONAL POWER AT AC-53A, 380/400 V, 50 HZ	1.1 kW
RATED OPERATIONAL VOLTAGE	42 - 550 V 500 V AC
SWITCHING LEVEL	-3 - 9.6 V DC, Switching level "Low", Actuating circuit (ON, L, R) 19.2 - 30 V DC, Switching level "High", Actuating circuit (ON, L, R) < 5 V DC, Switching level "confirm Off", Actuating circuit (ON, L, R)

AGAINST ELECTRIC SHOCK	entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	2.5 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION DETAILS	If necessary, Allow for derating
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	3 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	2 W

Electro magnetic compatibility

RADIO INTERFERENCE CLASS	EN 55011 Class A (EN 61000-6-3, emitted interference, radiated)
---------------------------------	--

Features & functions

FUNCTIONS

Controlled stop
DOL starting
For connecting to SmartWire-DT for expanded diagnostics
Temperature compensated overload protection
Motor protection
Automatic reset
Display of Device Type
Display of Enable signal
Manual reset
Display of Motor current in %
Display of Operating

General information	
CLASS	CLASS 10
CONNECTION TO SMARTWIRE-DT	Yes
DEGREE OF PROTECTION	IP20 NEMA Other
MODEL	Direct starter
MOUNTING METHOD	Rail mounting possible Top-hat rail fixing (according to IEC/EN 60715, 35 mm)
MOUNTING POSITION	Vertical Motor feeder at bottom
OVERLOAD RELEASE CURRENT SETTING - MAX	3 A
OVERLOAD RELEASE CURRENT SETTING - MIN	0.18 A
PRODUCT CATEGORY	Electronic motor starter
PROTOCOL	Other bus systems
RESIDUAL RIPPLE	≤ 5 % (input voltage)
TERMINAL CAPACITY	0.2 - 2.5 mm ² , Main cables, Push-in terminals
TERMINAL CAPACITY (AWG)	24 - 14, Push-in terminals
TYPE	DOL starter (complete device)
VOLTAGE TYPE	DC

direction feedback
Operating the motor starter
Display of Operational readiness
Display of Overload prewarning
Display of Set short-circuit release value
Display of Thermal motor image in %
Display of Trip indications (overload, phase failure, etc.)

Safety	
EXPLOSION SAFETY CATEGORY FOR DUST	ATEX dust-ex-protection, II (2) G [Ex e] [Ex d] [Ex px] ATEX dust-ex-protection, II (2) D [Ex t] [Ex p]
SAFETY PARAMETER (EN ISO 13849-1)	3, Category PL e, Performance level 60 (safe switch off) / 82 (motor protection) years; MTTFD
SAFETY PARAMETER (IEC 62061)	Opening delay [ms]: 200 (safe switch off) / Class 10 (motor protection) 99 % (safe switch off) / 98 % (motor protection), DC

Resources

APPLICATION NOTES	eaton-motor-starter-ems2-setting-motor-protection-twincat3-ap034001-en-us.pdf
BROCHURES	eaton-ems2-electronic-motorstarter-brochure-br034001en-en-us.pdf
CHARACTERISTIC CURVE	eaton-contactors-ems2-reversing-starter-characteristic-curve.eps eaton-contactors-ems2-reversing-starter-characteristic-curve-003.eps
DECLARATIONS OF CONFORMITY	eaton-reversing-starter-declaration-of-conformity-uk251121en.pdf eaton-reversing-starter-declaration-of-conformity-eu250638en.pdf
DRAWINGS	eaton-contactors-ems2-reversing-starter-dimensions.eps eaton-contactors-ems2-reversing-starter-3d-drawing.eps
ECAD MODEL	DA-CE-ETN.EMS2-DOS-T-3-SWD
INSTALLATION INSTRUCTIONS	eaton-ems2-electronic-motor-starter-ems2-with-swd-instruction-leaflet-il120010ZU.pdf
INSTALLATION VIDEOS	Eaton's electronic motor starter EMS2
MANUALS AND USER GUIDES	eaton-electronic-motor-starter-ems2-swd-manual-mn120008en-us.pdf
MCAD MODEL	DA-CS-ems2_dos_ros_t_swd eaton-motor-starter-mcad-drawings-ems2-dos-ros-t-swd.dwg
SALES NOTES	eaton-rmq-chemical-resistance-flyer-fl047011en-en-us.pdf eaton-ems2-electronic-motorstarter-flyer-fl034007en-en-us.pdf

PROJECT NAME:
PROJECT NUMBER:
PREPARED BY:
DATE:



Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2026 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

