


Specifications



Eaton 226161

Eaton Moeller® series M22 Telescopic adapters

General specifications

PRODUCT NAME	Eaton Moeller® series M22 telescopic clip
CATALOG NUMBER	226161
MODEL CODE	M22-TA
EAN	4015082261610
PRODUCT LENGTH/DEPTH	80 mm
PRODUCT HEIGHT	40 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.043 kg
COMPLIANCES	CE Marked
CERTIFICATIONS	CSA Std. C22.2 No. 94-91 EN 60947-5 CSA Std. C22.2 No. 14-05 IEC 60947-5 UL 508 VDE UL CE CSA Class No.: 3211-03 UL Category Control No.: NKCR CSA-C22.2 No. 14-05 CSA File No.: 012528 CSA-C22.2 No. 94-91 IEC/EN 60947-5 CSA UL File No.: E29184



Powering Business Worldwide

Actuator

FITTED WITH: 35 mm top-hat rail
(according to IEC/EN 60715)

FUNCTIONS

For equalization of the mounting depth of rear mounting devices in CI enclosures, and in cabinets with mounting depths of 115 - 155 mm
For mounting of EASY, FAZ, PKZ, DIL etc. weighing ≤ 0.3 kg

Communication

CONNECTION TO SMARTWIRE-DT No

Climatic environmental conditions

AMBIENT OPERATING TEMPERATURE - MAX 70 °C

AMBIENT OPERATING TEMPERATURE - MIN -25 °C

Design verification

10.10 TEMPERATURE RISE Not applicable.

10.11 SHORT-CIRCUIT RATING Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 MECHANICAL FUNCTION The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

10.2.2 CORROSION RESISTANCE Meets the product standard's requirements.

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES Meets the product standard's requirements.

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT Meets the product standard's requirements.

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS Meets the product standard's requirements.

10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Please enquire

10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 MECHANICAL Does not apply, since the

IMPACT	entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER-FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
EQUIPMENT HEAT DISSIPATION, CURRENT-DEPENDENT PVID	0 W
HEAT DISSIPATION CAPACITY PDISS	0 W
HEAT DISSIPATION PER POLE, CURRENT-DEPENDENT PVID	0 W
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	0 A
STATIC HEAT DISSIPATION, NON-CURRENT-DEPENDENT PVS	0 W

General information

ACCESSORY/SPARE PART TYPE

Accessory

PRODUCT CATEGORY

- Accessories
- Compact PLCs
- Control relay easyRelay

USED WITH

PKE
EC4P
easy200/500/700/800
PKZM0
MFD-CP8

Resources

CATALOGUES

[eaton-pushbuttons-signal-towers-sensors-assortment-overview-catalog-ca047003en-en-us.pdf](#)

DRAWINGS

[eaton-operating-m22-indicator-light-dimensions.eps](#)
[eaton-operating-indication-m22-indicator-light-dimensions-002.eps](#)
[eaton-operating-m22-telescopic-clip-dimensions.eps](#)
[eaton-operating-m22-telescopic-clip-3d-drawing.eps](#)

ECAD MODEL

[ETN.226161.edz](#)

INSTALLATION INSTRUCTIONS

[IL04716002Z](#)

MCAD MODEL

[eaton-accessory-mcad-drawings-teleskop-adapter.dwg](#)
[teleskop_adapter.stp](#)

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:

DATE:



Eaton Corporation plc Eaton House
30 Pembroke Road
Dublin 4, Ireland
Eaton.com

© 2026 Eaton. All Rights Reserved.

Follow us on social media to get the latest product and support information.

